



CHHATTISGARH STATE POWER GENERATION COMPANY LIMITED
(A Govt. of C.G. Undertaking)

No.03-01/ SE-III/ 1294

Raipur, Dtd: 9 NOV 2020

To,

The System Analyst,
EITC, Shed No.4,
CSPDCL
Danganiya, Raipur (C.G).

Sub:- Information for uploading tender documents of No.-03-01/SE-III/TS-11/Gangrel HEP Dt 09/11/2020 in the official website of CSPGCL.

With reference to above, please find enclosed herewith a copy of above mentioned Tender Notice giving full details for display in CSPGCL's WEBSITE.

Please arrange to display above tender notice in CSPGCL's website immediately under intimation to this office.

Encl:-1. As above

4
SUPERINTENDING ENGINEER (Gen)
O/o EXECUTIVE DIRECTOR (O&M:Gen)
C.S.P.G.C.L, RAIPUR.

Copy to:

1, The ED(O&M:GEN) CSPGCL Raipur

CHHATTISGARH STATE POWER GENERATION COMPANY LIMITED

(A Govt. of C.G. Undertaking)

9 NOV 2020

No.-03-01/SE-III/TS-11/Gangrel HEP/ 1293

Raipur, Dt 09 /11/2020

NOTICE INVITING TENDER : 03-01/SE-III/TS-11/Gangrel HEP/2020-21

Sealed tenders are invited from the reputed and experienced manufacturer/dealers/suppliers/firms for the “ Supply of the fire fighting equipments at 4X2.5 MW Gangrel HEP,Rudri,Dhamtari(CG) CSPGCL .” as per the list enclosed with this notice. :-

Tender documents shall be obtained from the office of the undersigned, by submitting crossed DD/Bankers Cheque (non-refundable) of amount Rs 224/- drawn in favour of **Assistant Manager (CAU) CSPGCL, Raipur CSPGCL, Raipur** payable at Raipur. on working day during working hours. Direct payment will not be entertained by this office. Important dates in respect of above NIT is given below:-

Last date of Tender Submission	: 01.12.2020, 15:30 Hrs
Date of tender opening	: 01.12.2020, 16:00 Hrs
Tender Document Cost	: Rs 224 /-
Earnest Money Deposit (EMD)	: Rs 4400 /-

A. IMPORTANT POINTS FOR THE BIDDERS:

1. Tender document can be obtained from the O/o E.D (O&M:Gen), CSPGCL, Raipur by making a written request along with the authorization letter issued on the letter head of the company and payment of the Tender Fee (non refundable) through MICR Demand Draft/banker's cheque only, in favour of “Assistant Manager (CAU), CSPGCL, Raipur” payable at Raipur. **Tender without tender fee shall be liable for rejection.**
 - * Postal charges of Rs. 100/- extra shall be paid, if tender document is required by post.
 - * It is obligatory to purchase the tender document, otherwise offers will not be accepted.
 - * Tender document is not transferable.
2. The CSPGCL will not be responsible for late receipt of tender/ offer due to any postal delay and offers received after the due date & time of submission will not be considered.
3. In case any of the above prescribed dates is declared as holiday, then the particular date will automatically get shifted to the next working day. Sealed tender will be accepted till 15:30 Hrs on the due date of opening and will be opened at 16.00 Hrs on the same day.
4. CSPGCL reserves the right to accept or reject any or all tenders, incomplete tender or accept any tender in full or in part, considered advantageous to CSPGCL, whether it is lowest or not, without assigning any reason whatsoever.

B. INSTRUCTIONS TO BIDDERS / TENDERERS :-

1. Date of submission of tender is : 01.12..2020 **till 15:30 Hrs.** and date of opening of tender is at **16.00 Hrs** on the same date in the O/o E.D (O&M:GEN), CSPGCL, Raipur.
2. Earnest Money:- The Earnest Money of Rs.4400/- (Rupees Eight Hundred only) is to be submitted in the form of MICR Demand Draft in favour of **Assistant Manager (CAU)CSPGCL, Raipur** payable at Raipur.

CHHATTISGARH STATE POWER GENERATION COMPANY LIMITED

(A Govt. of C.G. Undertaking)

3. **Qualifying conditions for the bidders:-** The price Bids of only those bidders shall be opened who will provide satisfactory documentary evidence to substantiate following Qualification Requirements (Eligibility criteria conditions for opening of Price Bids). The desired documents to substantiate Qualification Requirements (Eligibility criteria conditions for opening of Price Bids) are to be attached in Techno-Commercial bid: Qualifying Requirement (Eligibility criteria for opening of Price Bid)

PQR	
Conditions of PQR	Document required in PQR
The bidder should be OEM/ authorized dealers or suppliers of reputed make for Firefighting equipments.	The bidder has to submit self attested copy of- certificate/authorization letter issued by company for the same. The supplier should submit the order copy for the supply of similar type of fire fighting equipments.

- Any bidder may be disqualified, if he makes misleading or false representations in the forms, statements and attachments submitted in proof of the qualification requirements and/ or record of poor performance such as not properly completing the contract, litigation history or financial failures etc.
- The quoted rates must be on FIRM basis and should be valid for a period of 04 months from the date of opening of tender part-I & part-II.
- The offers of those tenderer, who do not agree to C.S.P.G.C.L's standard payments terms, security deposit clause, penalty clause & guarantee clause, shall be liable for rejection .
- PRICE BID has to be submitted in prescribed format only.
- Tender should be submit in the O/o ED(O&M:Gen), CSPGCL, Vidyut Sewa Bhavan,Danganiya,Raipur(CG) .
- Material to be supplied at 4X2.5 MW Gangrel HEP, Rudri, Dhamtari (CG)
- The rates quoted in the price bid shall be taken as final for computing the competitive rates and for all purpose, no corrections in quoted rates shall be allowed L1 Bidder will be consider on composite offer basis.
- Detailed technical specification of items to be supplied is mentioned in the tender specification document, if required .

SUPERINTENDING ENGINEER (Gen)
O/o EXECUTIVE DIRECTOR (O&M:Gen)
C.S.P.G.C.L, RAIPUR

CHHATTISGARH STATE POWER GENERATION COMPANY LIMITED

(A Govt. of C.G. Undertaking)

LIST

Subject : Supply of the fire equipments at 4X2.5 MW Gangrel HEP, Rudri, Dhamtari(CG)

CSPGCL

NOTICE INVITING TENDER : -03-01/SE-III /TS-11/Gangrel HEP/2020-21

SNo	Particular	Qty(No)
1	ABC Type Dry Chemical powder (6 L) Mono Ammonium Phosphate powder conforming to IS:14609. Nitrogen Pressurized. Controllable discharge Mechanism. Pressure Gauge. Discharge Hose & Nozzle. Epoxy Polyester Powder Coated as per IS: 15683 ISI Mark Fire extinguisher. Fire Rating (3A. 89B), Operating Temperature (-)20°C to +60°C suitable for "A" "B" "C" Class of FIRE Extinguisher conforming to IS: 15683 with ISI mark	22
2	Mechanical Foam Type Fire Extinguishers (9 L) (Stored Pressure Type) AFFF Foam 6% conforming to IS: 4989, Discharge Mechanism. Pressure Gauge. Discharge Hose & Nozzle Epoxy Polyester Powder coated as per IS: 15683 ISI mark Fire Extinguishers. Operating Temperature (-)5°C to (+)60°C. Fire Rating 4A. 144B, Suitable for AB Class of fire.	13
3	Water Type Fire Extinguisher (9 L) (Stored Pressure Type). Nitrogen Pressurized. Discharge Mechanism. Pressure Gauge. Discharge Hose & Nozzle Epoxy Polyester Powder coated as per IS: 15683 ISI mark Fire Extinguishers. Fire rating 4A Operating Temperature (-)5°C to (+)60°C. Suitable for A Class Fire Extinguisher conforming to IS 15683 with ISI mark	10
4	Carbon Dioxide type Fire Extinguisher (9 kg) Gas conforming to IS:15222 Cylinder conforming to IS:7285 & PESO approved. Controllable Discharge Mechanism, Discharge Hose & Horn suitable for B, C Class of fire. Fire Rating (55B) Extinguisher conforming to IS: 16018 with ISI mark	12
5	Carbon Dioxide type Fire Extinguisher (4.5 kg) Gas conforming to IS: 15222, Cylinder conforming to IS:7285 & PESO approved, Discharge Hose & Horn as per IS: 15683 with ISI mark. Fire extinguisher. Operating Temperature 20°C to 60°C, Fire Rating (55B) suitable for B, C Class of Fire Extinguisher conforming to IS: 15683 with ISI mark.	21
6	Fire Bucket Capacity: 9 Ltr with handle made by 22 gauge MS sheet duly painted by Red oxide enamel paint	14
7	HOSE PIPE (63mm dia x 15 mtr long) Reinforced Fabric rubber lined delivery, in conformity to ISS:636 Type-A with ISI mark, with Stainless Steel Male & Female instantaneous Coupling with binding by copper wire	14

TERMS& CONDITIONS :-

1. Extinguisher shall confirm in general to relevant IS documents or its latest amendments. Test certificate of all items except item 6 shall be submitted alongwith delivery of material.
2. Prior to acceptance of Fire Extinguishers sample testing of fire extinguisher may be carried out.

4
SE(GEN)