

CIN- U40108CT2003SGCO15820



**CHHATISGARH STATE POWER TRANS. CO. LTD.**  
(A Govt. of Chhattishgarh undertaking) (A successor company of CSEB)

**O/o Chief Engineer (Store & Purchase)**  
3<sup>rd</sup> Floor, SLDC Building, Dangania, Raipur(C.G.)-492013

Phone-0771-2574236/40  
Fax-0771-2574246

Website- [www.cspc.co.in](http://www.cspc.co.in),  
Email id :-narendra.bisen2010@gmail.com  
No. 02-16/CE(S&P)/TR-20/S&P/35/

Raipur, dtd **4 JAN 2021**

**Corrigendum**

**Sub: Tender specification No. TR-20/S&P/35 for Procurement of Thermovision Camera for EHV S/s under PSDF Scheme .**

The terms & conditions of NIT No. 02-16/SE(I-S&P)/TR-20/S&P/08/35/1729 Raipur, dtd 29.12.2020 for Procurement of Thermovision Camera for EHV S/s under PSDF Scheme may be read as mentioned below :-

S. N.	Clause No./ PageNo.	As per tender specification	Amended Requirement
1	<b>SECTION -II (TECHNICAL SPECIFICATION FOR THERMAL IMAGING CAMERA AND ACCESSORIES)</b>		
	CI.No.- 6.0 Sr. No. (1) Display at page No. 29	Minimum 3.5", Colour, Touch Screen,LCD/TFT Display with sunshield/backlight, rotatable display minimum 180°.	Minimum 3.5", Colour, Touch Screen,LCD/TFT Display with sunshield/backlight, rotatable display or lense minimum 180°.
2	CI.No.- 6.0 Sr. No. (2) IR Detector Type & Size at page No. 29	Uncooled micro bolometer Focal Plane array with IR detector size of 640 X 480 pixels and with super resolution / image enhancement technology the thermal resolution should be 1280x960 pixels.	Uncooled micro bolometer Focal Plane array with IR detector size of 320 X 240 pixels and with super resolution / image enhancement technology the thermal resolution should be 640x480 pixels.
	Sr. No. (9) at page No. 36	Please confirm that the temperature range is in the range of : -20 °C to 1000°C	Please confirm that the temperature range is in the range of : -20 °C to 600°C

All other terms & conditions of tender TR-20/S&P/35 will remain unchanged.

(Er. S.D.Telang)  
Chief Engineer (Store & Purchase)  
C.S. Power Transmission Co. Ltd., Raipur

Copy to:-

1. The Chief Engineer (EITC), CSPDCL, Raipur. - It is requested to please arrange publication of corrigendum in the web site of CSPTCL.