

CHHATTISGARH STATE POWER TRANS. CO. LTD.

(A Govt. of Chhattisgarh undertaking) (A successor company of CSEB)

CIN- U40108CT2003SGCO15820 / GSTIN-22AADCC5773E1ZX

O/o Chief Engineer (Stores & Purchase)

3rd Floor, SLDC Building, Dangania, Raipur(C.G.)-492013 Website- www.cspc.co.in

Phone-0771-2574240/36

email- nk.bisen@cspc.co.in

Fax-0771-2574246

No.02-16/SE-I(S&P)/TR-20/S&P/42/

No 3094 -

Raipur, dtd.

27 FEB 2021

CORRIGENDUM-2

TENDER NO.TR-20/S&P/42,

E-bidding (RFX No. 8100019951)


Sub: Tender specification No. TR-20/S&P/42 for procurement of 33/0.415 KV,200 KVA & 630 KVA Station Transformers E-bidding (RFX No. 8100019951) - Corrigendum thereof.

The terms & conditions of NIT No.02-16/SE-I(S&P)/ TR-20/S&P/42/27/36/1827 Dtd: 11.01.2021 for procurement of 33/0.415 KV,200 KVA & 630 KVA Station Transformers are amended/added as hereunder:-

Sl. No	Para /Tender Clause No./ Page No.	Requirement as per tender specification	Amended Requirement
1	Para 91(A) clause 1.4 & 2.2/ Tender Section I (A), Instruction to Bidders , clause 5 (A) 1.4 & 2.2 ,page 9	<p>1.4 The bidder should have all type test/special test reports conducted as per relevant standards i.e. ISS/ IEC carried out at & issued by Govt. Standard laboratory/ NABL accredited laboratory /ILAC accredited Laboratories on tendered material/equipment offered as per tender specification. The type test/special test report of tendered item i.e. should not be older than five (05) years as on the date of issue of NIT. Further, the type test report furnished for different 'Type & Rating' of tendered item other than specification shall not be considered valid.</p> <p>2.2 The bidder should have all type test/special test reports conducted as per relevant standards i.e. ISS/ IEC carried out at & issued by Govt. Standard laboratory/</p>	<p>1.4 The bidder should have all type test/special test reports conducted as per relevant standards i.e. ISS/ IEC carried out at & issued by Govt. Standard laboratory/ NABL accredited laboratory /ILAC accredited Laboratories on station transformer 33/0.415 KV rating. The type test/special test report of station transformer 33/0.415 KV rating i.e. should not be older than five (05) years as on the date of issue of NIT.</p> <p>2.2 The bidder should have all type test/special test reports conducted as per relevant standards i.e. ISS/ IEC carried out at & issued by Govt. Standard laboratory/</p>

		NABL accredited laboratory /ILAC accredited Laboratories on tendered material/equipment offered as per tender specification. The type test/special test report of tendered item i.e. should not be older than five (05) years as on the date of issue of NIT. Further, the type test report furnished for different 'Type & Rating' of tendered item other than specification shall not be considered valid.	NABL accredited laboratory /ILAC accredited Laboratories on station transformer .33/0.415 KV rating . The type test/special test report of station transformer 33/0.415 KV rating i.e. should not be older than five (05) years as on the date of issue of NIT.
2	Para 91 (D) clause 1.4 Tender Section I (A), The following documents should be submitted in support of Pre-Qualifying requirement , clause 1.4. Page 12	1.4 The bidder should have all type test/special test reports conducted as per relevant standards i.e. ISS/ IEC carried out at & issued by Govt. Standard laboratory/ NABL accredited laboratory /ILAC accredited Laboratories on tendered material/equipment offered as per tender specification. The type test/special test report of tendered item i.e. should not be older than five (05) years as on the date of issue of NIT. Further, the type test report furnished for different 'Type & Rating' of tendered item other than specification shall not be considered valid.	1.4 The bidder should have all type test/special test reports conducted as per relevant standards i.e. ISS/ IEC carried out at & issued by Govt. Standard laboratory/ NABL accredited laboratory /ILAC accredited Laboratories on station transformer .33/0.415 KV rating. The type test/special test report of station transformer 33/0.415 KV rating i.e. should not be older than five (05) years as on the date of issue of NIT.

All other terms and conditions of the tender no. **TR-20/S&P/42** shall remain unchanged & applicable .


Chief Engineer (S&P)
CSPTCL, Raipur

Copy to:-

1. The CE (EITC), CSPDCL, Raipur –Please arrange to place/display the aforesaid corrigendum of tender TR-20/S&P/42 on the CSPTCL's website.