



CHHATTISGARH STATE POWER TRANSMISSION. CO. LTD.
(A Govt. of Chhattishgarh undertaking) (A successor company of CSEB)

CIN- U40108CT2003SGCO15820 / GSTIN-22AADCC5773E1ZX

O/o Chief Engineer (Store & Purchase)

Address :- Third Floor, SLDC Building, Dangania, Raipur(C.G.)-492013

Website- www.cspc.co.in, Email- arbunkar1501@gmail.com, Phone-0771-2574239/09, Fax-0771-2574246

No./02-16/SE-II/ TR-20/S&P/37/

No 3 0 2 2 -

Raipur, Dtd:

16 FEB 2021

CORRIGENDUM

Tender No.:- TR-20/S&P/37.

Material:- Online tower footing earth impedance tester

Due date of submission of tender :- 27.02.2021 up to 15.00 Hrs.

With reference to the tender no. TR-20/S&P/37, inviting bids for the procurement of Online tower footing earth impedance tester. The technical specification at page 29 &30 of tender document may read as below –

Technical Specification:-

Specified in tender document TR-20/S&P/37 1	Corrigendum 2
	Column (1) May be read as
<u>S.No-4 of Section-III(TECHNICAL SPECIFICATIONS OF TOWER FOOTING EARTH RESISTANCE, INDUCTANCE AND INPEDANCE TESTER) at page 29 of tender document</u> 4 TEST FREQUENCY Should be high frequency equipment. <i>Test Frequency should be 25 KHz</i>	<u>S.No-4 of Section-III(TECHNICAL SPECIFICATIONS OF TOWER FOOTING EARTH RESISTANCE, INDUCTANCE AND INPEDANCE TESTER) at page 29 of tender document</u> 4 TEST FREQUENCY Should be high frequency equipment. <i>Test Frequency should be 25 KHz or Impulse Method.</i>
GUARANTEED TECHNICAL PARTICULARS FOR THE TOWER FOOTING EARTH RESISTANCE AND IMPEDANCE TESTER at page 30 of tender document 3. Test Current – 20 mA. 5. Measurement Range- 0 to 300 ohms. 10. Memory- Instrument should have internal memory storage up to 2000 results. 15. Other Features:- 1. Inbuilt Printer 2. GPS Location tagging	GUARANTEED TECHNICAL PARTICULARS FOR THE TOWER FOOTING EARTH RESISTANCE AND IMPEDANCE TESTER at page 30 of tender document 3. Test Current – 200 mA. 5. Measurement Range- 0 to 200 ohms 10. Memory- Instrument should have internal memory storage up to MIN. 990 results. 15. Other Features:- Inbuilt GPS with Location tagging

All other pre qualifying requirement and tender terms and conditions are kept same as mentioned in tender document TR-20/S&P/37.

(Er. S. D. Telang)
Chief Engineer (Store and Purchase)
C.S.P.T.C.L., Raipur

Copy to:-

1. The Chief Engineer (EITC), CSPDCL, Raipur.

- It is requested to arrange publication of corrigendum in the web site of CSPCL.