



**CHHATTISGARH STATE POWER TRANSMISSION. CO. LTD.**  
(A Govt. of Chhattishgarh undertaking) (A successor company of CSEB)  
**CIN- U40108CT2003SGCO15820 / GSTIN-22AADCC5773E1ZX**

**O/o Chief Engineer (Store & Purchase)**

**Address :- Third Floor, SLDC Building, Dangania, Raipur(C.G.)-492013**

Website- [www.cspc.co.in](http://www.cspc.co.in), Email- [arbunkar1501@gmail.com](mailto:arbunkar1501@gmail.com), Phone-0771-2574239/09, Fax-0771-2574246

No./02-16/SE-II/ TR-20/S&P/43/

Raipur, Dtd: 18 FEB 2021

No 30427  
**CORRIGENDUM**

**Tender No.:- TR-20/S&P/43.**

**Material:-** offline overhead fault locator and line signature analyzer kit

**Due date of submission of tender :-** 04.03.2021 up to 15.00 Hrs.

With reference to the tender no. TR-20/S&P/43, inviting bids for the procurement of Online tower footing earth impedance tester. The technical specification at page 31 & 32 of tender document may read as below –

**Technical Specification:-**

<b>Specified in tender document TR-20/S&amp;P/43</b>	<b>Corrigendum</b>
<b>1</b>	<b>2</b>
	<b>Column (1) May be read as</b>
<b>S.No-8 of Section-III ( TECHNICAL SPECIFICATIONI FOR THE OFFLINE OVERHEAD LINE FAULT LOCATION &amp; ANALYSER SYSTEM ) at page 31 of tender document</b>	<b>S.No-8 of Section-III ( TECHNICAL SPECIFICATIONI FOR THE OFFLINE OVERHEAD LINE FAULT LOCATION &amp; ANALYSER SYSTEM ) at page 31 of tender document</b>
<b>8. Accuracy of reading/ calibration</b> Resolutoin of +/- 1-- meters	<b>8. Accuracy of reading/ calibration</b> Resolution of +/- 100 meters
<b>B. 3-PHASE HEAVY DUTY ADAPTER UNIT at page 32 of tender document</b> * Complete suppression of all Induced voltages from adjuacent charged lines includng double circuit / Multi icircuit line. Up to 100 KCV measureble	<b>B. 3-PHASE HEAVY DUTY ADAPTER UNIT at page 32 of tender document</b> * Complete suppression of all Induced voltages from adjacent charged lines including double circuit / Multi circuit line up to 100 KV measurable

All other pre qualifying requirement and tender terms and conditions are kept same as mentioned in tender document TR-20/S&P/43.

  
( Er. S. D. Telang )  
Chief Engineer (Store and Purchase)  
C.S.P.T.C.L., Raipur

Copy to:-

1. The Chief Engineer (EITC), CSPDCL, Raipur.  
- It is requested to arrange publication of corrigendum in the web site of CSPCL.