



**CHHATTISGARH STATE POWER TRANSMISSION CO. LTD**  
 (A Govt. of Chhattisgarh undertaking) (A successor company of CSEB)  
**CIN- U40108CT2003SGCO15820 / GSTIN-22AADCC5773E1ZX**

**O/o Executive Director (Store & Purchase)**

Third floor, SLDC Building, Danganiya Raipur-492013.

Website- [www.cspc.co.in](http://www.cspc.co.in),

Phone-0771-2574240

Email id :- [nk.bisen@cspc.co.in](mailto:nk.bisen@cspc.co.in)

Fax-0771-2574246

No.02-16/SE-I(S&P)/TR-20/S&P/56/

**No 0184-1**

Raipur, Dtd

**CORRIGENDUM**

**21 MAY 2021**

**Sub: Tender specification No. TR-20/S&P/56 for supply of 132KV Control & relay Panels for Feeder,Transformer & Incomer Panel for 220/132 KV Transformer**

The terms & conditions of NIT No.02-16/SE-I(S&P)/TR-20/S&P/56/45/44/90 dt 07.05.2021 for supply of 132KV Control & relay Panels for Feeder,Transformer & Incomer Panel for 220/132 KV Transformer may be read as mentioned below :-

Sl. No.	Clause No./ Page No.	Requirement as per tender specification	Amended Requirement	Remarks								
<b>CORRIGENDUM</b>												
1	Annexure A, clause Section-II page 69	<table border="1"> <tr> <td colspan="2">The details of make/model of numerical relays</td> </tr> <tr> <td>Numerical distance protection relay with IRIG-B port</td> <td>GE (Alstom)-MicomP442 or higher/SEL 311C or higher/GE D-60 or higher /Siemens 7SA 611 or higher/Schneider-Micom-P442 or higher.</td> </tr> </table>	The details of make/model of numerical relays		Numerical distance protection relay with IRIG-B port	GE (Alstom)-MicomP442 or higher/SEL 311C or higher/GE D-60 or higher /Siemens 7SA 611 or higher/Schneider-Micom-P442 or higher.	<table border="1"> <tr> <td colspan="2">The details of make/model of numerical relays</td> </tr> <tr> <td>Numerical distance protection relay with IRIG-B port</td> <td>GE (Alstom)-MicomP442 or higher/SEL 311C or higher/GE D-60 or higher /Siemens 7SA 611 or higher/Schneider-Micom-P442 or higher.</td> </tr> </table>	The details of make/model of numerical relays		Numerical distance protection relay with IRIG-B port	GE (Alstom)-MicomP442 or higher/SEL 311C or higher/GE D-60 or higher /Siemens 7SA 611 or higher/Schneider-Micom-P442 or higher.	GE MiCOM P40 Agile P14D & P14N series are included in the models of relays for Numerical directional & Non directional O/c & E/f relay, REF relay& LBB relay
The details of make/model of numerical relays												
Numerical distance protection relay with IRIG-B port	GE (Alstom)-MicomP442 or higher/SEL 311C or higher/GE D-60 or higher /Siemens 7SA 611 or higher/Schneider-Micom-P442 or higher.											
The details of make/model of numerical relays												
Numerical distance protection relay with IRIG-B port	GE (Alstom)-MicomP442 or higher/SEL 311C or higher/GE D-60 or higher /Siemens 7SA 611 or higher/Schneider-Micom-P442 or higher.											

	Numerical transformer differential protection relay with IRIG-B port	GE (Alstom)-Micom P 642 or higher/SEL 487-E or higher/Siemens 7UT 633 or higher / GE T-60 or higher/Schneider-Micom P642 or higher.	Numerical transformer differential protection relay with IRIG-B port	GE (Alstom)-Micom P 642 or higher/SEL 487-E or higher/Siemens 7UT 633 or higher / GE T-60 or higher/Schneider-Micom P642 or higher.	
	Numerical directional O/C and E/F protection relay	GE (Alstom) Micom P141 or higher/Siemens - 7SJ66 or higher/Schneider Micom P141 or higher/GE F650 or higher.	Numerical directional O/C and E/F protection relay	GE (Alstom) Micom P141 or higher/Siemens - 7SJ66 or higher/Schneider Micom P141 or higher/GE F650 or higher./ <b>GE MiCOM P40 Agile P14D or higher</b>	

		Numerical non-directional O/C and E/F protection relay	GE (Alstom) Micom P141 or higher / Siemens 7SJ66/ Schneider Micom P141/ GE F650 or higher.		Numerical non-directional O/C and E/F protection relay	GE (Alstom) Micom P141 or higher / Siemens 7SJ66/ Schneider Micom P141/ GE F650 or higher./ <b>GE MiCOM P40 Agile P14N or higher</b>	
		LBB relay & Over load relay	GE (Alstom) Micom P141 or higher / Siemens 7SJ66/ Schneider Micom P141/GE C60.		LBB relay & Over load relay	GE (Alstom) Micom P141 or higher / Siemens 7SJ66/ Schneider Micom P141/GE C60/ <b>GE MiCOM P40 Agile P14N or higher</b>	

	REF relay	GE (Alstom) Micom P141 or higher / Siemens 7SJ66/ Schneider Micom P141/GE C60.		REF relay	GE (Alstom) Micom P141 or higher / Siemens 7SJ66/ Schneider Micom P141/GE C60/ GE MiCOM P40 Agile P14N or higher.	
--	-----------	--	--	-----------	---	--

All other terms & conditions of tender TR-20/S&P/56 will remain unchanged.

  
Executive Director (Store & Purchase)  
C.S. Power Transmission Co. Ltd., Raipur

Copy to:-

1. The Executive Director (EITC), CSPDCL, Raipur.  
- It is requested to please arrange publication of NIT in the web site of CSPTCL.