



CHHATISGARH STATE POWER TRANS. CO. LTD.
(A Govt. of Chhattishgarh undertaking) (A successor company of CSEB)
O/o Executive Director (Store & Purchase)
3rd Floor, SLDC Building, Danganla, Raipur(C.G.)-492013
Phone-0771-2574236/40 Fax-0771-2574246

Website- www.cspc.co.in.

No. CE/S&P/NIT/TR-21/09/

No 0717

Raipur, dtd

31 JUL 2021

Corrigendum

Sub: Tender specification No. TR-21/S&P/09 for supply of battery charger.

The terms & conditions of NIT No.02-16/SE-I(S&P)/TR-21/S&P/09/ 0639 Dtd 19.07.2021 for supply of battery charger may be read as mentioned below :-

S.n	Clause No./ Page No.	As per tender specification		Amended Requirement	
		Requirements	110 V 300 Ah	Requirements	110 V 300 Ah
1	Clause No. 1.3 of Section II (Page No.33)	TRICKLE CHARGER UNIT		TRICKLE CHARGER UNIT	
		1.Load (Amperes)	24/30	1.Load (Amperes)	24
		2.Trickle current (mAmps)	300	2.Trickle current (mAmps)	300
		3.Total design rating of trickle charger	25/31	3.Total design rating of trickle charger	25
		BOOST CHARGER UNIT		BOOST CHARGER UNIT	
		1. Load (Amperes).	24/30	1. Load (Amperes).	24
		2. Boost Current(Amps)	30	2. Boost Current(Amps)	30
		3.Total Requirement (Amps)	54/60	3.Total Requirement (Amps)	54

All other terms & conditions of tender TR-21/S&P/09 will remain unchanged.

(Er. I.L.Dewangan)
Executive Director (Store & Purchase)
C.S. Power Transmission Co. Ltd., Raipur

Copy to:-

The Chief Engineer (EITC), CSPDCL, Raipur. - It is requested to please arrange publication of corrigendum in the web site of CSPPTCL