



CHHATTISGARH STATE POWER TRANS. CO. LTD.

(A Govt. of Chhattishgarh undertaking) (A successor company of CSEB)

CIN- U40108CT2003SGC015820 /GSTIN:22AADCC5773E1ZX

O/o Executive Director (Store & Purchase)

Address :- Third Floor, SLDC Building, Dangania, Raipur(C.G.)-492013

Website- www.cspc.co.in Phone-0771-2574236/40 Fax-0771-2574246

No.02-16/SE-I(S&P)/TR-21/S&P/04/ Raipur, Dtd:

CORRIGENDUM

27 SEP 2021

Sub: Tender No.TR-21/S&P/04 for procurement of 315 MVA, 400/220/33 KV Autotransformers

The terms & conditions of NIT No.02-16/NIT/TR-21/S&P/04/722 dtd 02.08.2021 for supply of **315 MVA, 400/220/33 KV Autotransformer** may be read as mentioned below :-

Sl. No.	Clause No./ Page No.	PQR as per tender specification	Amended Requirement
1	Section -I, General Instructions to bidders, clause 4.3.3 , (Page 21)	<p>Delivery period: The delivery should be completed in Seven months from the date of order .</p> <p>The time for and date of delivery of the stores stipulated in the order shall be deemed to be the essence of the contract. In case of delay in execution of the order, the CSPTCL shall either:-</p> <p>i) Recover from the supplier as agreed Penalty / liquidated damages at the rate mentioned in "Penalty" clause.</p> <p>ii) Cancel the contract and purchase elsewhere on account and at the risk of the supplier, the stores not delivered.</p>	<p>Delivery period: The delivery should be completed in Eleven months from the date of receipt of drawing approval along with manufacturing clearance from CSPTCL</p> <p>The time for and date of delivery of the stores stipulated in the order shall be deemed to be the essence of the contract. In case of delay in execution of the order, the CSPTCL shall either:-</p> <p>i) Recover from the supplier as agreed Penalty / liquidated damages at the rate mentioned in "Penalty" clause.</p> <p>ii) Cancel the contract and purchase elsewhere on account and at the risk of the supplier, the stores not delivered.</p>
2	Section II/ Technical specification ,clause 4.8 (Page 34)	<p>Rated current of HV side at (-)10% volts tap & what will be the Temp. Rise & Losses if 10% continuous over loading done on (-) 10% tap.</p>	<p>Rated current of IV side at (-)10% volts tap & what will be the Temp. Rise & Losses if 10% continuous over loading done on (-) 10% tap shall be furnished by the bidder.</p>

All other terms & conditions of tender TR-21/S&P/04 will remain unchanged.

Executive Director (Store & Purchase)
CSPTCL : Raipur

Copy to:-

- The Chief Engineer (EITC), CSPDCL, Raipur.
- It is requested to please arrange publication of NIT in the web site of CSPTCL.