



CHHATTISGARH STATE POWER TRANS. CO. LTD.

(A Govt. of Chhattishgarh undertaking) (A successor company of CSEB)

CIN- U40108CT2003SGC015820 /GSTIN:22AADCC5773E1ZX

O/o Executive Director (Store & Purchase)

Address :- Third Floor, SLDC Building, Dangania, Raipur(C.G.)-492013

Website- www.cspc.co.in

Phone-0771-2574236/40

Fax-0771-2574246

No.02-16/SE-I(S&P)/TR-21/S&P/04/

7232 = Raipur, Dtd:

CORRIGENDUM-II

-6 OCT 2021

Sub: Tender No.TR-21/S&P/04 for procurement of 315 MVA, 400/220/33 KV Autotransformers

The terms & conditions of NIT No.02-16/NIT/TR-21/S&P/04/722 dtd 02.08.2021 for supply of **315 MVA, 400/220/33 KV Autotransformer** may be read as mentioned below :-

Sl. No.	Clause No./ Page No.	Required as per tender	Amended Requirement
1	Section -II, Technical Specifications, clause 11, (Page 79)	IMPORTANT:- Please note that in the instant case the 315 MVA transformer is being procured for existing 400 KV Khedamara Substation. The existing foundation of 315 MVA at 400 KV Khedamara (Bhilai) Substation is fitted with 03 Nos rails for weight bearing of transformer. Therefore the design of base of the new transformer should be such that it can be placed on 03 Nos existing rails . The drawing of existing foundation of 315 MVA transformer at 400 KV Khedamara Substation is attached as per ANNEXURE-XV,page141.	IMPORTANT:- Please note that in the instant case the 315 MVA transformer is being procured for existing 400 KV Khedamara Substation. The design of base of the new transformer should be such that it can be placed on 04 Nos rails.

All other terms & conditions of tender TR-21/S&P/04 will remain unchanged.

Executive Director (Store & Purchase)
CSPTCL : Raipur

Copy to:-

1. The Chief Engineer (EITC), CSPDCL, Raipur.

- It is requested to please arrange publication of NIT in the web site of CSPTCL.