



CHHATTISGARH STATE POWER TRANS. CO. LTD.

(A Govt. of Chhattisgarh undertaking) (A successor company of CSEB)

CIN- U40108CT2003SGCO15820 / GSTIN-22AADCC5773E1ZX

O/o Executive Director (Stores & Purchase)

3rd Floor, SLDC Building, CSPTCL Dangania, Raipur(C.G.)-492013

Website- www.cspc.co.in email- ar.bunker@cspc.co.in Phone-0771-2574240/47/4106

No.02-16/CE/TR-21/S&P/32/

No 1 3 8 7 -

Raipur, dtd.

2/9 OCT 2021

CORRIGENDUM- 1

TENDER NO.TR-21/S&P/32, E-bidding (RFX No. 8100023472)

Sub:- Tender specification No. TR-21/S&P/32 for Procurement of 150 Watt LED Flood Light Complete Fitting/ Fixture For Various EHV Sub-Station E-bidding (RFX No.-8100023472) due for opening on date i.e. 01/11/2021 - **Corrigendum thereof.**

The terms & conditions of NIT No.02-16/ED/ TR-21/S&P/32/1307 Raipur, Dtd: 21.10.2021 for Procurement of 150 Watt LED Flood Light Complete Fitting/ Fixture For Various EHV Sub-Station (**Schedule-II(A), Guarantee Technical Particular**) are amended as hereunder:-

S.N.	Schedule-II(A), GTP of the instant tender TR-21/S&P/32 at page 24 & 27	Amendment Schedule-II(A), GTP of the instant tender TR-21/S&P/32
	Schedule-II(A) Guarantee Technical Particular for 150 Watt LED Flood Light Complete Fitting/ Fixture For Various EHV Sub-Station(Tender Document at page 24 & 27)	
11	LED Driver & LED Lighting Fixture Driver should be isolated and IP 67 coated type and BIS R No. for LED fixture as well as LED Driver.	LED Driver & LED Lighting Fixture Driver should be isolated and IP 66 coated type and BIS R No. for LED fixture as well as LED Driver.

All other terms and conditions of the Tender No. TR-21/S&P/32 shall remain unchanged & applicable .


Executive Director (S&P)
CSPTCL, Raipur

Copy to:-

1. The CE (EITC), CSPDCL, Raipur –Please arrange to place/display the aforesaid corrigendum of tender TR-21/S&P/32 on the CSPTCL's website.