


CHHATISGARH STATE POWER TRANS. CO. LTD.

(A Govt. of Chhattishgarh undertaking) (A successor company of CSEB)

O/o Chief Engineer (Store & Purchase)

 3rd Floor, SLDC Building, Dangania, Raipur(C.G.)-492013

 Website- www.cspc.co.in,

Email id :-narendra.bisen2010@gmail.com

Phone-0771-2574236/40

Fax-0771-2574246

No. 02-16/CE(S&P)/TR-20/S&P/11/

Raipur, dtd

Corrigendum

22 JUL 2020

Sub: Tender specification No. TR-20/S&P/11 for Procurement of Thermovision Camera for EHV S/s under PSDF Scheme .

The terms & conditions of NIT No. 02-16/SE(S&P)/TR-19/49,20/03-04-05-11/321 Raipur, dtd 15.06.2020 for Procurement of Thermovision Camera for EHV S/s under PSDF Scheme may be read as mentioned below :-

S. N.	Clause No./ PageNo.	As per tender specification	Amended Requirement
1	SECTION -II (TECHNICAL SPECIFICATION FOR THERMAL IMAGING CAMERA AND ACCESSORIES)		
	Cl.No.- 6.0 Sr. No. (1) Display at page No. 31	Minimum 3.5", Colour, Touch Screen,LCD/TFT Display with sunshield/backlight, rotatable display minimum 180°.	Minimum 3.5", Colour, Touch Screen,LCD/TFT Display with sunshield/backlight, rotatable display or lense minimum 180°.
	Cl.No.- 6.0 Sr. No. (2) IR Detector Type & Size at page No. 31	Uncooled micro bolometer Focal Plane array with IR detector size of 640 X 480 pixels and with super resolution / image enhancement technology the thermal resolution should be 1280x960 pixels.	Uncooled micro bolometer Focal Plane array with IR detector size of 320 X 240 pixels and with super resolution / image enhancement technology the thermal resolution should be 640x480 pixels.
2	SCHEDULE-II (B-2) (TECHNICAL QUESTIONNAIRE FOR THERMAL IMAGING CAMERA)		
	Sr. No. (9) at page No. 38	Please confirm that the temperature range is in the range of : -20 °C to 1000°C	Please confirm that the temperature range is in the range of : -20 °C to 600°C

All other terms & conditions of tender TR-20/S&P/11 will remain unchanged.

(Er. S.D.Telang)

 Chief Engineer (Store & Purchase)
 C.S. Power Transmission Co. Ltd., Raipur

Copy to:-

1. The Chief Engineer (EITC), CSPDCL, Raipur. - It is requested to please arrange publication of corrigendum in the web site of CSPTCL.