

CHHATTISGARH STATE POWER
TRANSMISSION CO. LTD.

OFFICE OF THE CHIEF ENGINEER (S&P)
C.S.P.TRANS.C.L., DANGANIA, RAIPUR: 492013 (C.G.)

Phone No. 0771-2574236, 2574240

TENDER ENQUIRY No. 47/487

(e-Bidding)

**SUPPLY OF HIGH VOLTAGE CLAMP ON AMMETER (TONG TESTER) WITH HOT
STICK UNDER PSDF SCHEME**

RFx No. 8100018061

LAST DATE & TIME OF SUBMISSION OF TENDER
23.07.2020 (TIME 15:00 HRS.)

DUE DATE OF OPENING OF TENDER
23.07.2020 (TIME 15:30 HRS.)

**PRICE Rs. 560/- (Inclusive of 12%
GST) if Purchase from O/o C.E. (S&P)**
**& Rs. 590/- (Inclusive of 18%
GST) if downloaded**

For website

CHHATTISGARH STATE POWER TRANSMISSION COMPANY LIMITED

(A Government of Chhattisgarh Undertaking)

OFFICE OF CHIEF ENGINEER (S&P)

Address : 3rd Floor, LD Building, Dangania-Raipur (CG)-492013

Website: www.cspc.co.in

Tele.No.0771-2574236

No. 02-16/SE(S&P-I)/Enq. No. 47/481

Raipur, dtd. 02/07/2020

e-PROCUREMENT TENDER NOTICE

Sealed tenders are invited from Experienced Manufacturers/ **Authorized Dealers only** for supply of following materials:-

S.No.	Enq. No.	Particulars	Qty. in Nos.	Cost of tender doc. (Rs.)	EMD in Rs.	Due date
1	Enq. No. 02-16/SE(I)/Enq.No. 47 RFX No.8100018061	High Voltage Clamp on ammeter (Tong Tester) with hot stick	01	i) Rs. 560/- (Incl. 12% GST)Purchase from O/o CE (S&P) ii) Rs. 590/- (Incl. 18% GST) if downloaded from website)	6000/-	23.07.2020

In case any of the above dates is declared as holiday then the particular date will automatically get shifted to next working day.

- i) The quantities mentioned above are tentative & may vary according to final requirement.
- ii) Any notice for extension of due date of tender opening shall not be published in newspapers. It will be displayed only on official website of the company.
- iii) The tender will be processed through e-bidding module of SAP-SRM. Bidders are advised to visit our website www.cspc.co.in/csptcl for viewing detailed instructions regarding submission of offer through SAP-SRM.

TERMS AND CONDITIONS:-

- i) The tender documents can be obtained from the office of the C.E. (S&P), CSPTCL, Raipur in person on payment of cost of tender document in the form of MICR D.D. only made out in the name of Manager, RAO (HQ), CSPTCL, Raipur accompanied with firm's application on its letter head on any working day one day before the due date. If tender document is required by post, Rs.250/- is to be paid by D.D. along with the cost of documents. If more than one tender document is required, separate DDs should be furnished for each tender. CSPTCL shall not be responsible for any postal delay regarding receipt/non-receipt of tender documents.
- ii) The tender document will be made available on CSPTCL web site www.cspc.co.in. The bidder participating in the tender can download the document from web site. In such case, the cost of tender document in the form as detailed above be submitted along with the tender in EMD envelop. In absence of same, the tender shall not be opened.
The bidders who download the documents are requested to remain in contact with this office for any development in the tender.
- iii) Tender documents and the detailed specification could be issued on any working day up to the last date of sale of tender document. The duly filled tenders should be dropped in the tender box of the respective tender up to 15:00 hrs. on the due date. In case of tenders sent through post/ courier, it will be responsibility of the bidder to drop/get dropped the tender in the respective tender box. No receipt of the tender shall be issued in any case. The T.C. bid shall be opened at 15.30 Hrs. on above date.
- iv) After publication of NIT & before the date of opening of TC bid, corrigendum/ other information (if any) shall be displayed on our official web only. The bidders are requested to remain in contact with this office or visit our web-site for any development/ clarification/ amendment issued subsequently.
- v) CSPTCL reserves the right to accept or reject any or all the offers, in part or full without assigning any reason whatsoever.

Website www.cspc.co.in
(Go through CSPTCL-Tender notice)

Chief Engineer (S&P)
CSPTCL, Raipur

Special Instructions to bidders for submission of bid through SAP- SRM module (e-bidding)

The tender No. 02-16/SE(I)/Enq. No. 47/481 Raipur, dtd.02.07.2020 is to be processed through e-bidding. The bid is to be submitted online as well as offline (hard copy). Details of NIT & Tender Documents are available on our website—<http://www.cspc.co.in> & <http://ebidding.cspcl.co.in:50700/irj/portal>. The bidder may download the same from the above site. In e-bidding portal, tender documents will be displayed in online tender display at Technical RFx section.

Last date & time of submission of bid in hard copy and also in softcopy is 23.07.2020 upto 3.00 pm and due date & time of opening of the tender is 23.07.2020 at 3.30 pm.

Important Instructions :-

1. Please note that this tender shall be processed online as well as offline. The bidder has to submit all the documents in hard copy as per tender specifications in three envelopes. Besides above, scanned copy of following documents are to be uploaded in e-bidding portal:-
 - (a) The scanned copy of DD for tender fee.
 - (b) The scanned copy of DD for EMD/ EMD exemption.

It may please be noted that only above mentioned documents are to be uploaded in e-bidding portal and no other document is required to be submitted in e-bidding portal. The bidder shall give reply to following questions regarding above documents in e-bidding portal:-

- (i) Whether scanned copy of tender fee DD uploaded. Yes/No
 - (ii) Whether scanned copy of DD of EMD /EMD Exemption uploaded. Yes/No
3. It is not required to upload/attach scanned copy of price bid in Soft/Hard copy. Only the rates are to be filled in the item tab in e-cid in SAP SRM System (online e0tender). Rates should be quoted online & in specified fields only. Once the rates are filled, the bidders may change their rates up to the due date and time of submission of tender. After due date and time, no change on any ground whatsoever will be accepted.
 2. After scrutiny of techno-commercial bid, the price bid will be opened in e-bidding system only of eligible bidders for which suitable intimation will be given to the bidders offline & through email. C.E.(S&P), CSPTCL Tender Enq. No. 47/481 for Procurement of **High Voltage Clamp on Ammeter (Tong Tester) with hot stick under PSDF scheme for various EHV Sub-stations.**
 3. Please note that e-mail is always system generated, hence bidders are advised to regularly check their inbox/junk mail box.
 4. CSPTCL shall not assume any responsibility for non-supporting of system, internet, line & associated hardware & software for bidding their tender. No extension in time shall be granted on such grounds. The bidder should submit their bid well before submission dead line to avoid any system related problem. It is strongly recommended not to wait for submission of bid in last minutes as internet/technical problem may disrupt their works.
 5. Reference time for submission dead line shall be the time displayed in the portal and shall be treated as final.
 6. After end of submission dead line, no alteration in the tender will be allowed by the system. However, in case of extension of due date of opening of tender, the bidders will be allowed to submit revised bid in the system.
 7. CSPTCL will not accept incomplete bid.

8. The bidder must have a valid Digital Signature & SAP SRM User ID. User ID & Password from CSPTCL and Digital Signing Certificate and Digital Encryption Certificate from any recognized digital signature issuing authority are required for participation in any Tender. The bidder shall intimate in advance regarding details of digital signature issuing authority for ensuring the reliability of the same. For User ID and Password for participating in the tender, the bidder shall register on line through e-bidding portal.
10. The e-bidding vendor user manual displayed on website- <http://ebidding.cspcl.co.in:50700/irj/portal> for the help of the bidders. For any further queries the bidder may contact at Helpline no. 0771-2576672/73 (EITC, CSPDCL, Raipur)
11. The training for bidders will be on every Wednesday from 3.00 pm to 5.00 pm at office premises of Energy Info Tech Center (EITC) at Dangania, Raipur.
12. Tender shall be opened in the scheduled time as notified. If the due date of opening/submission of tender documents is declared a holiday by the Govt. or local administration, it will be automatically shifted to next working day for which no prior intimation shall be given. Tender opening shall be continued on subsequent days, in case the opening of all tenders is not completed on due date because of the technical constraints of system on the day of opening. It may be noted that the due date of opening/time may be altered/ extended if desired by CSPTCL without assigning any reason. However, intimation shall be available on company's tender portal/bidders email (if participation shown). The bidders are requested to keep track of the same.
13. Amendment in tender specification will be published on our website as well as in SRM system and the intimation regarding amendment in date extension will be conveyed through system generated e-mail to registered bidders only.
14. Before participating the bidder shall carefully read all the instructions and processes.
15. Tender duly completed in all respects will be accepted online up to due date & time and will be opened on the due date at specified time in the presence of bidders or their C.E.(S&P), CSPTCL Tender Enq. No. 47/481 for supply of **High Voltage Clamp on Ammeter (Tong Tester) with hot stick under PSDF scheme for various EHV Sub-stations**. Tender should reach the office of The Chief Engineer (S&P), CSPTCL authorized representatives. In case of authorized representative(s) they shall bring the original authorization letter with their signature attested by the bidder.

Chief Engineer (S&P)
CSPTrans.CL : Raipur

Pre-Qualifying Requirement:- The offer of those tenderers, who fulfill following criteria, will only be considered:

- 1) The bidding is open to Manufacturer/ Authorized Dealer of the tendered item. Necessary documentary evidences attested by Notary should be submitted in support of it.

- 2) The Bidder should have experience of supplying the tendered item to State Electricity Boards/Power Companies/NTPC/ PGCIL/ BHEL etc./Transformer manufacturing units/Testing labs line CPRI,ERDA etc. Necessary documentary evidences attested by Notary should be submitted in support of it.

CHHATTISGARH STATE POWER TRANSMISSION COMPANY LIMITED

(A Government of Chhattisgarh Undertaking)

OFFICE OF CHIEF ENGINEER (S&P)

Address : 3rd Floor, LD Building, Dangania-Raipur (CG)-492013

Website: www.cspc.co.in

Fax :0771-2574246,

Tele.No.0771-2574236

No. 02-16/SE(I)/Enq. No./47/481

Raipur, dtd. 02.07.2020

Purchase of **High Voltage Clamp on Ammeter (Tong Tester) with hot stick under PSDF scheme for various EHV Sub-stations** as mentioned in e-tender notice and offer for due for submission on dt. 23.07.2020 up to 15.00 Hrs. & to be opened on same date i.e. 23.07.2020 (15.30 Hrs.)

EARNEST MONEY DEPOSIT: Rs. 6000.00 (Rs. Six Thousand only)

Tender cost Rs. 560.00 (Rs. Five hundred sixty) if purchased from this office and Rs. 590/- (Rs. Five hundred ninety) if downloaded only {**Non refundable**}

ISSUED :

M/s. _____

Sold vide M.R. No. _____ Dated _____ for Rs. 560.00 (Rs. Five Hundred sixty) only .

Note :-

- (1) This complete form must be returned at the time of submitting the sealed tender Envelope duly super scribed "Tender Name, Tender No., Due date of opening, Firm's name & address in the O/o C.E.(S&P), CSPTCL, Dangania, Raipur within scheduled time/date otherwise tender shall be liable for rejection.
- (2) The tender should be submitted in the office having minimum THREE envelops Namely as under:-
 - Sealed Envelop-1:** For Earnest Money only duly super scribed "Tender Name, tender No., due date of opening & Firm's name seal & address (Part-I).
 - Sealed Envelop-2:** Prescribed document along with TERMS & CONDITIONS duly super scribed "Tender Name, No., due date of opening etc.
 - Sealed Envelop-3** Price bid only.

SE(I)

O/o Chief Engineer (S&P)

CSPTrans.CL : Raipur

SCHEDULE-I

PRICE BID IN SEPARATE ENVELOPS

Tender specification No. 02-16/SE(I)/Enq. No./47/481 Raipur, dtd. 02.07.2020, due for submission on dt. 23.07.2020 up to 15.00 Hrs. & to be opened on dt. 23.07.2020 (15.30 Hrs.)
EMD REQUIRED Rs. 6000.00 (Rs. Six thousand only).

The undersigned hereby tender and officer to CSPTCL to supply the material for the quantity at the rates as indicated here under:-

S.No.	Specification of Material (As per tender)	Qty . in sets	Unit Ex-works price inclusive of packing, forwarding, charges (Rs. /Unit)	Freight Charge s per Unit (Rs.)	GST on Ex-works Price+ Freight charges ---% in Rs.	Total Unit FOR D price including packing, forwarding, freight charges & GST (In Rs.)	Total Amt. in Rs.
1	High Voltage Clamp on Ammeter (Tong Tester) with hot stick, 0 to 220 KV 50 Hz, 1 Amp-400 Amp, having basic accuracy of $\pm 1\%$ ± 2 counts and resolution. 0 Amp to 99.9 Amp: 0.1 Amp and 100 Amp to 400 Amp:a Amp. Jaw size: ≥ 3.75 inches	01					

The undersigned undertake to observe and abide by the terms & condition at the tender specification enclosed herewith.

Earnest money of Rs. 6000.00 (Rs. Six Thousand) only has been deposited to the **Manager (RAO:HQ), CSPTCL:Raipur (C.G.)** vide M.R. No. _____ dtd. _____ / D.D. No. _____ dtd. _____ Drawn _____ (Name of Bank) .

Place:
Date:

Signature of bidders
Name
Address
Seal

Other Terms and Conditions (if any)

- 1) FOR:
- 2) Taxes:
- 3) Validity:.....
- 4) Delivery:.....
- 5) Payment:.....
- 6) Security Deposit:.....
- 7) Others:.....

Details of Bidders

- 1) Name of firm/partners & Address :-----
:-----
:-----
- 2) Phone /Mobile No :-----
- 3) GST Registration No. :-----
- 4) PF No. if any :-----
- 5) ESI Registration No. (If applicable) :-----
- 6) PAN (Mandatory) :-----
- 7) SAP Vendor No. :-----
- 8) Vender Registration No. :-----

C.I.N. : U40108CT2003SGC015820

CHHATTISGARH STATE POWER TRANSMISSION COMPANY LIMITED

(A Government of Chhattisgarh Undertaking)

OFFICE OF THE CHIEF ENGINEER (S&P)

Address : 3rd Floor, LD Building, Dangania-Raipur (CG)-492013

Website:www.cspc.co.in

Fax :0771-2574246, Tele.No.0771-2574239

02-16/SE(I)/e-Enq. No./47/481

Raipur, dtd. 02.072020

Due On 23.07.2020

SECTION-I

GENERAL TERMS & CONDITIONS OF TENDER SPECIFICATION.

- 1) Sealed tenders quotation are invited by The Chief Engineer (S&P), CSPTCL: Raipur, for supply of **High Voltage Clamp on Ammeter (Tong Tester) with hot stick under PSDF scheme for various EHV Sub-stations.**
- 2) Tender should reach the office of The Chief Engineer (S&P), CSPTCL, Dangania Raipur, by **15.00 Hrs. on 23.07.2020.** Tenders received after the stipulated time / date will not be considered. Covers should invariably be superscribed for supply of **High Voltage Clamp on Ammeter (Tong Tester) with hot stick under PSDF scheme for various EHV Sub-stations** and should be accompanied with Bankers Cheque or DD payable in favor of The Manager (RAO:HQ) CSPTCL, Raipur (C.G.). The tender will be opened on the same day at 15.30 Hrs.
- 3) When tenders are delivered by special messenger it should be dropped in the "Tender Box" kept in the office of The Chief Engineer (S&P), CSPTCL, Daganiya Raipur on any working day between 10.30 Hrs. to 15.00 Hrs.
- 4) Full descriptive particulars and complete specifications should accompany the tender. Offers should be kept open for acceptance for at least three months from the date of opening. However in due circumstances beyond control bidders are advised to extend validity. However, they shall not be permitted to revise their rates.
- 5) The CSPTCL reserves the rights to reject any or all tenders or to accept any tender considered advantageous to the CSPTCL whether it is the lowest tender or not, and In case of correction done in the tender, the same should be initialed otherwise tenders may not be considered.
- 6) All the Bidders shall essentially indicate the break-up of prices as shown in tender form. In case any of the charges are not included in the quoted prices, the same shall be clearly shown as extra, indicating specifically the rate/scale of such charges.
- 7) The terms and conditions mentioned in tender specification shall be binding on all Bidders and no condition or stipulation contrary to our condition shall be applicable.
- 8) **EARNEST MONEY:** Each bidders should submit an earnest money of Rs. 6000/- (Rs. Six thousand) only.
The tenders not accompanied with earnest money will summarily be rejected.

9) FORM OF EARNEST MONEY DEPOSIT:--

The earnest money deposit can be furnished in any of the following forms.

- i. By Bankers cheque or DD on a schedule Bank at Raipur made payable to the Manager (RAO:HQ) CSPTCL, Raipur (C.G.).

Offers accompanied with inadequate earnest money will be rejected and returned unopened.

10) Exemption from payment of earnest money: -

- i. SSI Units of C.S./Ancillary Units of CSPTCL, for the items quoted these units must be registered.
- ii. "Fully owned state Government units" will qualify for this exemption only if 100% shares are held by the State Govt. concerned for which documentary evidence must be made available at the time of opening of tender.
- iii. In case of Small Scale Unit permanently registered with NSIC, their registration certificate should be valid for the items on tender on due date of opening.

11) SUBMISSION OF EARNEST MONEY DEPOSIT: -A separate envelope containing the earnest money or a certificate in support of claim for exemption from this should be attached with your offer duly super scribed Earnest Money Deposit in appropriate form against tender specification No. 02-16/SE(I)/Enq. No./47/481 Raipur, dtd. 02.07.2020 for supply of **High Voltage Clamp on Ammeter (Tong Tester) with hot stick** under PSDF scheme for various EHV Sub-stations

12) FORFEITURE OF EARNEST MONEY DEPOSIT: -

It should be clearly understood that in the event of Bidders failing to accept and execute the telegraphic and detailed orders, if it is placed within the validity period of the offer, the full amount of earnest money will be forfeited and CSPTCL decision in this respect will be final and binding on the Bidders.

13) EXTENSION ORDER: -

In the event of an order being placed on Bidders, he is requested give his concurrence that he is also willing to accept additional order on the same terms and conditions , if the extension order is placed by the **CSPTCL** within six months from the date of acceptance / placement of order.

14) PRICE :-The prices should be quoted F.O.R. Destination including packing, forwarding, freight , insurance , GST and any other charges.

15) PERFORMANCE GUARANTEE / DEFECTIVE SUPPLIES :-

If during the course of 12 months from the date of dispatch, any of the goods is found to be defective in materials or workmanship or develop defect in service, the same will be rectified by you free of all charges.

- 16) SECURITY DEPOSIT :-**
The successful Bidders shall deposit security at the rate of 10 % of the value of the order in the form of Bankers Cheque or Bank Draft in favour of “**Manager (RAO:HQ) CSPTCL, Raipur (C.G.).**”
- 17) PAYMENT :-**
100 % payment against receipt of the material in the STORES in good condition within a month shall be made by Manager (RAO:HQ) CSPTCL, Raipur (C.G.). No interest shall be payable in case of delay in payment.
- 19) PENALTY :-**
If the Bidders fails to supply the material within the specified time , the penalty shall be levied @ 0.5 % per week or part thereof up to maximum of 10 % on the value of unsupplied material .
- 20) MATERIALS :-**All materials supplied shall be as per tender specification.
- 21) DELIVERY :-**
The delivery shall be completed within specified days mentioned in the order from the date of receipt the tendered order.
- 22) CONSIGNEE:-**The Executive Engineer (Area Stores) CSPTCL, Bhilai/Bilaspur
- 23) SUBMISSION OF BILLS:-**
All the bills shall be submitted in triplicate to the E.E.(Area Stores), CSPTCL, Bhilai/Bilaspur
- 24) ANY DESPUTE ARISING:-** Out of the contract shall be subject to the jurisdiction of court at Raipur.
- 25)** The Chief Engineer (S&P), CSPTCL, Raipur (C.G.) reserve the right to amend or reject or the tender partially or fully or to change the Quantity of materials without assigning any reason, at any stage whatsoever

S.E. (I)
O/O C.E.(S&P) CSPTCL: RAIPUR

SCOPE :-

(A) Technical Specification of High Voltage Clamp On Ammeter (Tong Tester) with Hot Stick:-

1.0 SCOPE: The specification covers the design, manufacture , testing and supply of complete kit of HT tong tester for measurement of load on live line bare conductor.

2.0 TECHNICAL DATA FOR 0 - 220 KV HT TONG TESTER (Ammeter) :-

- (a) **High voltage clamp on Ammeter (Tong tester) with hot stick , 0 to 220 KV , 50 Hz, 0 Amp. - 400 Amp. , having basic accuracy of $\pm 1\% \pm 2$ counts , having resolution 0 Amp. to 99.9 Amp. : 0.1 Amp. and 100 Amp. to 400 Amp. : 1 Amp. , suitable for accurate measurement .**
- (b) **High voltage clamp on Ammeter (Tong tester) having Wide Jaw ; Jaw Width should be ≥ 3.75 inches.**
- (c) **The tong tester shall be capable of storing minimum three readings .**
- (d) **Hot Stick : Ammeter (Tong tester) with hot stick should be suitable for 220 KV system Voltage.**
- (e) **Full working length of Hot Stick (suitable for 220 KV system Voltage) not less than 18 feet along with two pairs of 220 KV Rubber Hand Gloves with Company Test Certificates.**

S.E. (I)
D/O CE (SSP), CSPTCL
Raipur

SCOPE :-

(A) Technical Specification of High Voltage Clamp On Ammeter (Tong Tester) with Hot Stick:-

1.0 SCOPE: The specification covers the design, manufacture , testing and supply of complete kit of HT tong tester for measurement of load on live line bare conductor.

2.0 TECHNICAL DATA FOR 0 - 220 KV HT TONG TESTER (Ammeter) :-

- (a) **High voltage clamp on Ammeter (Tong tester) with hot stick , 0 to 220 KV , 50 Hz, 0 Amp. - 400 Amp. , having basic accuracy of $\pm 1\% \pm 2$ counts , having resolution 0 Amp. to 99.9 Amp. : 0.1 Amp. and 100 Amp. to 400 Amp. : 1 Amp. , suitable for accurate measurement .**
- (b) High voltage clamp on Ammeter (Tong tester) having Wide Jaw; Jaw Width should be ≥ 3.75 inches.
- (c) **The tong tester shall be capable of storing minimum three readings .**
- (d) **Hot Stick : Ammeter (Tong tester) with hot stick should be suitable for 220 KV system Voltage.**
- (e) Full working length of Hot Stick (suitable for 220 KV system Voltage) not less than **18 feet** along with **two pairs** of 220 KV Rubber Hand Gloves with **Company Test Certificates.**

S.E. (I)
D/O CE (SSP), CSPTCL
Raipur

TECHNICAL SCHEDULE
**TECHNICAL PARTICULARS FOR HIGH VOLTAGE CLAMP ONAMMETER (TONG -
 TESTER) WITH HOT STICK.**

Sl. No.	Particulars	Desired Specification	Offered Specification
1.	Make	Reputed Make	
2.	Range Of Operation	Voltage 0 – 220 KV Current 0 – 400 Amp.	
3.	Operation Frequency	50 Hz (47 to 53 Hz)	
4.	Resolution	0 Amp. — 99.9 Amp. : 0.1 Amp. 100 Amp. — 400 Amp. : 1 Amp.	
5.	Accuracy	± 1% ± 2 counts	
6.	Sensor Opening	Wide Jaw	
7.	Opening Width Of Jaw	≥ 3.75 inches	
8.	Controls	One Button Operation	
9.	Operating Temperature	-30 Deg Cel to + 60 Deg Cel (22 Deg F to 140 Deg F)	
10.	Display	3.5 Digit Display	
11.	Reading Storage Capacity	Minimum Three Reading Storage Capacity	
12.	Weight	Please Indicate	
13.	Housing	Shock & Water Resistant molded urethane, Flame resistant housing	
14.	Hot Stick	Suitable for 220 KV System Voltage ; Minimum 18 feet length ; along with two pairs of 220 KV Rubber Hand Gloves with Company Test Certificates.	
15.	Carrying Case	Hard Carrying Case should be provided	
16.	Guarantee Period	Should be 12 months from the date of Material Receipt	
17.	Test & Calibration Certificate	Should be provided with the instrument	
18.	Safety & Protection Standard	CE conformity ; In case of Other Standards : Please Indicate	

SE(I)
 O/DUE (S&P), CSPTCL
 Raipur

