

**CHHATTISGARH STATE POWER TRANSMISSION CO. LTD**

(A Government of Chhattisgarh Undertaking)

Office of the Chief Engineer (Planning & Projects)

Address : Third floor, SLDC Building, Danganiya Raipur-492013.

Website : www.cspc.co.in

Phone 0771-2574209/12

Fax:0771-2574246

No. 02-04/TL/TR-20/04/Corrigendum/ **No 482**

Raipur/dtd.

8 JUL 2020**CORRIGENDUM****TENDER NO.TR-20/04 (DUE FOR OPENING ON 15/07/2020)**

Sub:-Modification of 132 KV Railway Traction line Bilaspur (From existing Loc. no. 02 to Gantry) on Steel D/C Monopole (60-90° dev. bottom cross arm height 23M, dead end) due to construction of proposed Fly Over Bridge at Tifra (Bilaspur) (Tender No.TR-20/04).

Ref:- This office N.I.T. No.02-04/NIT/TR-20/04/ 415 Raipur/dtd.30.06.2020

The following clauses of tender No.TR-20/04 for Modification of 132 KV Railway Traction line Bilaspur (From existing Loc. no. 02 to Gantry) on Steel D/C Monopole (60-90° dev. bottom cross arm height 23M, dead end) due to construction of proposed Fly Over Bridge at Tifra (Bilaspur) (Tender No.TR-20/04) is incorporated/amended as hereunder:-

| S. N. | Clause No./Page No. in tender TR-20-04 | As mentioned in instant tender No. TR-20/04 | Clause amended/added and now may be read as |
|-------|--|---|---|
| 1 | Tender clause 1.4, Section-I under head "Instructions to Bidders" (Page No.21) | The bidder may deviate from the specification while quoting if in his opinion such deviation is in line with the manufacturer's standard practice and conducive to a better and more economical offer. All such deviations should however be clearly indicated giving full justifications for such deviation in separate sheet(s) under "Deviations" title in annexure. | 'No any technical & Commercial deviation is allowed in the instant tender' |
| 2 | Tender clause 4.23, Tender page No.72 under head "TYPE TESTS" | --- | 4.23.04 : Drawing submission & approval :- The successful bidder should submit the drawing of offered 132KV D/C monopole alongwith design calculation for approval of CSPTCL. The design calculation of 132KV DC monopole should be as per technical parameters specified for Steel Monopole mentioned in section-IV of the tender document (page 63 to 72). The design calculation of the monopole should be vetted by CPRI/ERDA or IIT (like IIT Mumbai/ Delhi/ Chennai/ Kanpur/ Kharagpur /Roorkee). The monopole should be supplied strictly as per the approved drawing/design. |

All other clauses, sub-clauses, terms & conditions of the tender shall remain unchanged.


Chief Engineer (P&P)
CSPTCL : RAIPUR