

CHHATTISGARH STATE POWER TRANSMISSION CO. LTD.

(A Govt. of Chhattisgarh undertaking) (A successor Company of CSEB)

O/o Chief Engineer (Planning & Projects)

Third floor, SLDC Building, Danganiya, Raipur-492013

Website :www.cspc.co.in

Phone 0771-2574245/ 14/ 09

Fax:0771-2574246

No. 02-04/NIT/TR-20/10/

No 1570

Raipur/dtd.

4 JAN 2021

// CORRIGENDUM-II //

Sub: Tender No. TR-20/10 (RFx No. 8100019500) for construction of 220/132KV S/s Patan (up-gradation of existing 132/33 KV S/S).

Ref: This office NIT No. 02-04/NIT/TR-20/10/1308 dt 02.12.2020.

With reference to the tender specification No. TR-20/10, the following clauses are hereby added/ amended:

Sl. No.	Clause No. of TR-20/10	As mentioned in Tender No. TR-20/10	Clause amended/ added and now may be read as
1	--	Communication equipment: EPAX (Exchange for 24 lines) Electronic Push Button telephone with Priority Key	Technical specifications for (i) EPAX and (ii) 4Cx10 sq mm copper cables have been added as Annexure-32 & Annexure-33 respectively in Tender document (Vol. II). (enclosed herewith)
2	Clause-4, sl. No.6 of Vol.-II	Technical Specifications of 160 MVA, 220/132/33 KV Power Transformer, vector group specified is YNyn0d11.	It is Auto transformer with tertiary, connection symbol (Vector group) is YNa0d11.

Further, the replies of queries raised by the bidders namely M/s. Amara Raja Power System Ltd., Hyderabad and M/s. Sterling & Wilson (P) Ltd., Mumbai are also enclosed herewith.

All other terms and conditions of the tender shall remain unchanged.


Chief Engineer (Planning & Projects)
C. S. Power Transmission Co. Ltd., Raipur

Copy to:

The CE (EITC), CSPDCL, Raipur : It is requested to display the Corrigendum-II on official website of CSPTCL against the tender No. TR-20/10.