



CHHATTISGARH STATE POWER TRANSMISSION CO. LTD.

(A Govt. of Chhattisgarh undertaking) (A successor Company of CSEB)

CIN- U40108CT2003SGC015820

Office of the Chief Engineer (Planning & Projects)

Dangania, Raipur (CG) 492 013

Ph.No. 0771- 2574245/ 4209

website: www.cspc.co.in/csptcl

Fax- 0771- 2574246

No. 02-04/SS1/TR-20/10/

No 1564

Raipur, dt.

2 JAN 2021

To,

PhNo. 91-22 2548530

M/s. Sterling & Wilson (P) Ltd.,
Universal Majestic, 9th floor,
P.L. Lokhande Marg,
Chembur (W),
MUMBAI – 400 043.

Sub: Tender No. TR-20/10 (RFx No. 8100019500) for construction of 220 KV sub-station Patan (Up gradation of existing 132/33 KV S/S Patan) on turnkey basis- Reply to the pre bid queries.

Ref: Your letter No. WR/T&D/CSPTCL/W-ES-20-21-0011 dt 24.12.2020.

Dear Sirs,

You have raised queries on tender specification No. TR 20/10 for construction of 220/132 KV sub-station Patan (Up gradation of existing 132/33 KV S/S Patan) on turnkey basis. The reply of the query is as given below:

Sr. No.	Section & Clause No.	Description as per specification	Queries	Clarification by CSPTCL
1	Technical Specifications of 160 MVA, 220/132/33 KV Power Transformer	The technical specification specifies the requirement of an auto transformer however the vector group specified is of Power Transformer YNyn0d11	Kindly confirm the type of transformer required i.e. either Power Transformer or Auto Transformer.	It is Auto transformer with tertiary, connection symbol (Vector group) is YNa0d11.

Thanking You,

Yours faithfully

Chief Engineer (Planning & Projects)
C. S. Power Transmission Co. Ltd., Raipur

Copy to:

The Chief Engineer (EITC), CSPDCL, Raipur

: For publication of corrigendum in power Companies Website against tender No.TR-20/10 of this office.