

CIN- U40108CT2003SGC015820

GSTIN-22AADCC5773E1ZX



**CHHATTISGARH STATE POWER TRANSMISSION CO. LTD.**

(A successor company of CSEB) (A Government of Chhattisgarh Undertaking)

**O/o Executive Director (Planning & Project)**

Address : Third floor, SLDC Building, Danganiya Raipur-492013.

Website : [www.cspc.co.in](http://www.cspc.co.in)

Phone: 0771-2574209/14/41

email: [cepnpcspc@csptcl.co.in](mailto:cepnpcspc@csptcl.co.in)

Fax: 0771-2574246

No.02-04/TR-21/01/Corri/

No 1296

Raipur/dt.

11 OCT 2021

// CLARIFICATION //

**Sub:** Construction of 220/132/33 KV sub-station at SEMARIYA (Distt.Durg) TR-21/01. (Through E-Bidding) (RFx No.- 8100022387).

**Ref.:** This office NIT No. 02-04/NIT/TR-21/01/833 dtd. 07.08.2021.

\*\*\*\*\*

With reference to above NIT for TR-21/01, Construction of 220/132/33 KV sub-station at SEMARIYA (Distt.Durg) TR-21/01. (Through E-Bidding) (RFx No.- 8100022387, the queries raised by various bidders in respect of technical specification of equipment / material and regarding other terms & conditions of the tender are clarified and the details are as per statement enclosed herewith.

Encl As above.

  
**Executive Director (Planning & Project)**  
**CSPTCL, Raipur**

**Copy to:**

The CE (EITC), CSPDCL, Raipur.

**Clarification sought by some of the prospective bidders in respect of technical specification of some equipments / material against tender No. TR-21/01 for construction of 220/132/33 KV S/S Semariya, Distt.-Durg**

**Details of modification / clarification sought by bidders and clarification of CSPTCL thereof.**

S.No.	Modification / clarification sought by bidders	Clarification of CSPTCL
1	To provide GA drawing/BOM for ACDB, DCDB, Junction Box and Marshalling Box as same is not available in tender document.	Technical Requirement / Specification are already given in Clause 30 (1.4) (page-384) in Volume-II of tender specification. The design of these items is in the scope of contractor.
2	To provide Model No./ Catalogue No. of individual lighting fixture as detailed in price bid annexure B-6 (Sl. No.1 to 7).	Details are provided in price bid annexure B-6 and the list of approved vendors are given in Section-V (D), Sl. No.14 & 19. It is not considered necessary to provide catalogue/model No. In respect of each items & vendors.However, engineering to be done by the bidder.
3	Relaxation towards the payment of security deposit/performance guarantee amount to be paid against various Govt./Semi-Govt. Projects which are getting executed/ to be executed in coming years. Govt. of India has relaxed performance BG amount to 3% max. of project value.	The terms & condition for payment of security deposit/ Performance Guarantee are already stipulated in tender document which shall remain unchanged and applicable.
4	To provide civil drawing for Loading/Unloading gantry & Air conditioned Bay Marshalling Room (with RCC roof).	Foundation drawings of Loading/Unloading gantry and Air conditioned bay marshalling room are already annexed with the folders of civil drawing as mentioned hereunder :- i) Drawing for foundation of loading/unloading gantry at Sl. No. 34 of civil drawing with the number 04-01/ST. ii) Drawing for Bay marshalling room as BMR 01 & BMR-02, Sl. No. 60 & 61 of civil drawing, drawing No. 04-012/ST/380.
5	i) To change in standard for Series Reactor for capacitor bank. ii) To allow to supply 333.33 KVAR, 6.9KV capacitor units in addition to 166.67KVAR, 6.93KV capacitor unit.	Tender specification for 12MVAR 36KV capacitor bank is stipulated in clause-18 of Volume-II of tender specification, which shall remain unchanged and applicable.
6	To provide dimension & drawing of octagonal pole.	The prices for octagonal pole with luminaries are required to be furnished in price bid schedule B-6, Sl. No.-7. Design & supply of structure is in the scope of the contractor.

  
Executive Director (Planning & Project)  
CSPTCL: Raipur